



# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name: Level Top PC Agg**

Product Sample Information		Certificate Information	
Company:	The Euclid Chemical Company	Certificate No:	200521-03
Company Website:	www.euclidchemical.com	Certified By:	 Raja S. Tannous, Laboratory Director
Product Type:	Floor Coatings or Adhesives	Date:	May 21, 2020
Date Produced:	4/20/2020		

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

### Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>		TVOC <sup>4</sup>
	Criterion	Compliant?	Criterion	Compliant?	
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	≤ 0.5 mg/m <sup>3</sup>
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	≤ 0.5 mg/m <sup>3</sup>

**Product Coverage<sup>5</sup>:** See attached letter – multiple layers applied

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m<sup>3</sup>, >0.5 – 4.9 mg/m<sup>3</sup>, and ≥5.0 mg/m<sup>3</sup>
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

### Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- USGBC LEED Version 4, BD&C, ID&C
- The WELL Building Standard
- ANSI/GBI 01, Green Building Assessment Protocol

**Narrative:** The Euclid Chemical Company selected a sample representative of its Level Top PC Agg concrete rehabilitation product and submitted it on 4/27/2020 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 1148-003-03A-May2120.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

**DISCLAIMER:** THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.



**EUCLID CHEMICAL**

**Technical Center**

The Euclid Chemical Company  
19320 Redwood Road  
Cleveland, OH 44110-2799

Phone: 800-321-7628

Fax: 216-531-9399

[www.euclidchemical.com](http://www.euclidchemical.com)

DATE: April 21, 2020

**Purpose / Procedure:**

A standard concrete mix with no admixture and 3/8" stone was prepared in a mold with dimensions of 8" x 8" x 1". The concrete slab was moist cured for 7 days. After 7 days, the concrete slab was dried and sandblasted to achieve a CSP-3. Euco Floor Epoxy Primer was then mixed and applied at 90 ft<sup>2</sup>/gal to the sandblasted concrete slab. 16-30 mesh sand was then broadcasted onto the Euco Floor Epoxy Primer at a rate of 1 lb/ft<sup>2</sup>. After 24 hours, the excess broadcasted sand was brushed away. Level Top PC Agg was then applied to the top of the sample. After Level Top PC Agg was fully cured the sample was then cut with a grinder. Eucosil was then applied to the surface of the cut Level Top PC Agg at 400 ft<sup>2</sup>/gal. After 24 hours Ultraguard was applied on top of Eucosil at 500ft<sup>2</sup>/gal. Sample was then allowed to cure for 24 hours. Sample was double wrapped in aluminum foil and shipped to Berkely Analytical on 4-21-2020 for VOC Emissions Test.

---

David W. Booth  
Formulator, Coatings and Adhesives